









## CROSS SECTION

PIPE SIZE CHART*				
DIAMETER	15"	18"	24"	30"
HEIGHT	2'-9"	3'-0"	3'-6"	4'-0"
WIDTH	4'-3"	4'-6"	5'-0"	5'-6"

<sup>\*</sup>ALL DIMENSION'S SHOWN ARE MINIMUMS.

## NOTES

- 1. IF CONDITIONS REQUIRE ANY VARIATION IN THE SIZE OF A WINGWALL, IT MUST FIRST BE APPROVED BY THE GOVERNMENTAL ENGINEER BEFORE CONSTRUCTION BEGINS.
- 2. ALL REINFORCING STEEL SHALL HAVE A 2" (MINIMUM) CONCRETE COVER.
- SEE PIPE SIZE CHART FOR DIMENSIONS ASSOCIATED WITH PIPE DIAMETERS.
- 4. A 1" CHAMFER SHALL BE USED ON EACH EXPOSED EDGE AND CORNER.
- 5. #4 BARS (TYPICAL) SHALL BE @ 1'-0" C.C. EACH WAY IN THE CENTER OF SLABS AND WALLS.

## CITY OF CHATTANOOGA AND HAMILTON COUNTY

CONCRETE ENDWALL (TYPE "W")

DATE OF ORIGINAL ISSUE
DECEMBER 10, 1999
STANE

STANDARD NUMBER: SD-604.01